



# Errata to IEEE Guide for Wind-Loading Evaluation of High-Voltage (>1000 V) Air-Break Switches

Developed by the  
**Switchgear Committee**  
of the  
**IEEE Power and Energy Society**

*Correction Sheet*  
**26 November 2019**

Copyright 2019 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved.  
Published 26 November 2019. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

***In subclause 5.3, page 16, change the first item of the “where” list in Equation (6) as follows:***

$$F_{WCI} = C \times C_F \times K_Z \times G_{RF} \times V^2 \times (D_I + (2 \times R_I)) \times H_T \quad (6)$$

where

$F_{WCI}$  is the wind force on insulator,  $N$  (lbf)

***In Annex A.5, page 22, change the tenth list item as follows:***

$$D_I = 10.98 \text{ in}$$

$$0.279 \text{ m}$$

***In Annex A.5, page 22, change the eleventh list item as follows:***

$$H_T = 128 \text{ in}$$

$$3.251 \text{ m}$$